WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 18342
Permit No.
Basin

1. OWNER Millard Constr ADDRESS 224 So Carson St C.C., New

2. LOCATION SE ¼ SW ¼ Sec. 11 T. 14 N/S R. 19 E. Douglas County
PERMIT NO. Alpineview Estates Lot #79

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	12	12
Sand	X	12	13	1
Sandy Clay		13	29	16
Sand & Gravel	X	29	33	4
Sandy Clay		33	49	16
Sand & Gravel	X	49	52	3
Sandy Clay		52	65	13
Sand & Gravel	X	65	71	6
Sandy Clay		71	75	4
Sand & Gravel	X	75	78	3
Sandy Clay		78	80	2

Date started 5-8-78, 19
Date completed 5-12-78, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 2 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12" 30' 30'-8" inches Total depth 80 feet
Casing record 8 5/8
Weight per foot 16.9 Thickness 188

Diameter	From	To
8 inches	0 feet	80 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3 x 3/32
From 67 feet to 77 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 10 Feet below land surface
Flow No G.P.M.
Water temperature Cold Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W M Blair
Address Box 353 Dayton, Nev 89403
Nevada contractor's license number 10950
Nevada driller's license number 757
Signed Charles Rohr
Date 6/9/78

USE ADDITIONAL SHEETS IF NECESSARY

5471