WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 18414
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Frank Rupert ADDRESS Box 142 Fernley Nev

2. LOCATION S1/2 ¼ NE ¼ Sec. 36 T. 20 N/S R. 25 E. Lyon County
PERMIT NO. Parcel #1

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silty sand & gravel		0	30	30
gray clay		30	180	150
brown red clay		180	300	120
blue clay		300	400	100
blue gray shale	✓	400	435	35

Date started June 12, 1978
Date completed June 19, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
650 CFM 250 PSI	10	130	4 HR

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10" To 50' 8 3/4 to bottom inches Total depth 435 feet
Casing record 6 5/8
Weight per foot 12.9 Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	435 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 435 feet

Perforations:
Type perforation factory
Size perforation 16 X 3
From 395 feet to 435 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 270 Feet below land surface
Flow 10 G.P.M.
Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Serv
Address Box 2143 Carson City
Nevada contractor's license number 14327
Nevada driller's license number 900
Signed Robert J Foster
Date June 22 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471

OFFICE
STATE ENGINEER

1978 JUN 26 AM 8 58

I