

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER John Daniels ADDRESS _____

2. LOCATION 1/4 1/4 Sec. 16 T. 19 N/S R. 12 E Washoe County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand & Clay</u>		<u>0</u>	<u>18</u>	<u>18</u>
<u>Sand</u>	<u>WB</u>	<u>18</u>	<u>20</u>	<u>2</u>
<u>Clay</u>		<u>20</u>	<u>61</u>	<u>41</u>
<u>Sand</u>	<u>WB</u>	<u>61</u>	<u>79</u>	<u>18</u>
<u>Clay</u>		<u>79</u>	<u>80</u>	<u>1</u>

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 80 feet
 Casing record 80
 Weight per foot _____ Thickness _____
 Diameter 6.8 inches From 0 feet To 80 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 80 feet
 Perforations:
 Type perforation factory
 Size perforation _____
 From 60 feet to 80 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 18 Feet below land surface 18
 Flow _____ G.P.M. 40
 Water temperature _____ ° F. Quality _____

Date started 6-29, 1978
 Date completed 7-2, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name James House Well Drilling
 Address Box 351 C.C.
 Nevada contractor's license number 12554
 Nevada driller's license number 800
 Signed James House
 Date 7-3-78

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours