

OFFICE USE ONLY
 Log No. 18547
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER WALTER J. GARRISON ADDRESS WAYSACK
LAMAR, NEV
 2. LOCATION S 1/4 S 1/4 Sec 14 T 33 N 8 R 56 E ELKO County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay, sand		0	15	15
Brown Clay		15	38	23
Sandy Clay	*	38	40	2
Brown sticky clay		40	60	20
Brown clay with stringers of sandstone		60	100	40
Stringers of sandstone 8" to 10" with stringers of sand & gravel	*	100	145	45
Sandstone		145	150	5

8. WELL CONSTRUCTION
 Diameter hole 1.00 inches Total depth 150 feet
 Casing record _____
 Weight per foot _____ Thickness 188

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>150</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement Grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 150 feet
 Perforations:
 Type perforation Footing Unit
 Size perforation 4 1/2"
 From 110 feet to 140 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 27 Feet below land surface
 Flow _____ G.P.M.
 Water temperature 60 ° F. Quality Good

Date started 6-27, 19 78
 Date completed 7-5, 19 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name OMG Well Drilling
 Address PO Box 41 - Elko, Nev 89801
 Nevada contractor's license number 4796
 Nevada driller's license number 115
 Signed [Signature]
 Date 7-17-78

BAILER TEST
 G.P.M. 20 Draw down 0 feet 1/2-hourly
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours