WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 18594
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER John Danlies ADDRESS Carson City, Nev.
Carson View Estates Lot 29
NW SW APN 010-321-12 #7 Raguin Ct.

2. LOCATION ~~N.E.~~ ¼ ~~S.E.~~ ¼ Sec. 28 T. 15 N/S R. 20 E. Carson City County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Clay		0	65	65
Sand	w/b	65	70	5
Sand & Clay		70	85	15
Sand	w/b	85	95	10
Sand & Clay		95	120	25
Coarse Sand	w/b	120	130	10
Clay		130	135	5

Date started 7/19/78, 19
Date completed 7/25/78, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 15 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 5/8 inches Total depth 135 feet
Casing record
Weight per foot Thickness 188

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal Fifty Feet feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 1/16
From 95 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 60 Feet below land surface
Flow G.P.M. 20
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jim House & Son's Drilling
Address P.O. Box 2192 Carson City
Nevada contractor's license number 12554
Nevada driller's license number 651
Signed Steve House
Date July 31, 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471