WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 18635
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER John Griffin ADDRESS 4115 Mira Loma Dr.
Reno, Nev. 89502

2. LOCATION NW ¼ NW ¼ Sec. 5 T. 17 N/S R. 21 E. Storey County
PERMIT NO. 886½ 1820 Cartwright Ave V.C. Highlands

TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well ☑ Recondition ☐	Domestic ☑ Irrigation ☐ Test ☐	Cable ☐ Rotary ☑
Deepen ☐ Other ☐	Municipal ☐ Industrial ☐ Stock ☐	Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Med. Hard Gray Formation		0	20	20
Soft Yellow "		20	40	20
Med. Hard Gray "		40	80	40
" " Brown "		80	90	10
" " Gray "		90	100	10
" " Lt. " "		100	115	15
Soft Brown "		115	120	5
" Yellow "		120	140	20
Med. Hard Gray "		140	170	30
" " Brown "		170	200	30
" " Yellow "		200	210	10
" " White "		210	310	100
" " Lt. Gray "	16GPM	310	395	85
" " Red "		395	400	5
" " Gray "		400	460	60
Fractures at 310'				
Small Amount Water				
Second Water				
Fractured at 400'				
Formation				

Date started 7-21, 1978
Date completed 7-31, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Now at This Time			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 10 & 8½ inches Total depth 460 feet
Casing record Steel
Weight per foot 13.52 Thickness .188

Diameter	From	To
6 5/8 inches	+1 feet	460 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑ Packer
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Spun Slot
Size perforation 18 x 3"
From 448 feet to 460 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 360 Feet below land surface
Flow 18 G.P.M. By Air ?
Water temperature C ° F. Quality Clear

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Richard Fritz
Address P.O. Box 903, Verdi, Nev.
Nevada contractor's license number 14251
Nevada driller's license number 943
Signed [signature]
Date 7-31-78

USE ADDITIONAL SHEETS IF NECESSARY

5471