

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Ernest + Constance Fry ADDRESS 3691 TR DR
WELLSINGTON, NEV 89144
 2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec. 8 T. 10 N/S R. 22E DOUGLAS County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------------------|--------------|------------|------------|------------|
| <u>Clay & Broken Rock</u> | | <u>1</u> | <u>52</u> | |
| <u>DG & Broken Rock</u> | | <u>53</u> | <u>64</u> | |
| <u>Broken Rock & Clay</u> | | <u>65</u> | <u>78</u> | |
| <u>DC</u> | | <u>79</u> | <u>83</u> | |
| <u>Clay & Broken Rock</u> | | <u>84</u> | <u>111</u> | |
| <u>DG & Broken Rock</u> | | <u>112</u> | <u>124</u> | |

8. WELL CONSTRUCTION
 Diameter hole 6.5 inches Total depth 124 feet
 Casing record 124
 Weight per foot _____ Thickness 58 + 66

| Diameter | From | To |
|---------------------|-----------------|-----------------|
| <u>6</u> inches | <u>1</u> feet | <u>58</u> feet |
| <u>5 7/8</u> inches | <u>91</u> feet | <u>107</u> feet |
| <u>5</u> inches | <u>107</u> feet | <u>124</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

 Surface seal: Yes No Type clean cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 91 feet
 Perforations:
 Type perforation factory
 Size perforation 1/4 1/4
 From 60 feet to 75 feet
 From 107 feet to 124 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ Feet below land surface 100
 Flow _____ G.P.M. 10
 Water temperature Cold ° F. Quality _____

Date started June 28 19 78
 Date completed June 28 19 78

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kawchep Pump & Well Inc
 Address Box 536 Gardnerville
 Nevada contractor's license number 95219
 Nevada driller's license number 933
 Signed Walter Kew
 Date June 28, 1978

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours