

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER Mrs. Robert Hess ADDRESS Goldenville, Nevada

2. LOCATION NE 1/4 SE 1/4 Sec. 26 T. 13 N/S R. 20 E Douglas County  
 PERMIT NO. Panel B

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silt some sand</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Clay + pebble stone Large gravel Very compact.</u>		<u>3</u>	<u>50</u>	<u>47</u>
<u>Clay + gravel The plain hard brown large gravel</u>		<u>50</u>	<u>90</u>	<u>40</u>
<u>Coarse sand + gravel + clay matrix.</u>		<u>90</u>	<u>140</u>	<u>50</u>
<u>Water at 115 raised to 95 -</u>				
				<u>140</u>

8. WELL CONSTRUCTION  
 Diameter hole 8 7/8 inches Total depth 140 feet  
 Casing record  
 Weight per foot 19 Thickness 188  

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
<u>8 7/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 + feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation 1/16 x 3 Factory  
 Size perforation \_\_\_\_\_  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 95 Feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature 58 ° F. Quality good

Date started Aug 15, 1978  
 Date completed Aug 18, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Arthur W. Graham  
 Address Goldville Nevada  
 Nevada contractor's license number 12953  
 Nevada driller's license number 751  
 Signed A.W. Graham  
 Date Aug 20 - 1978

BAILER TEST  
 G.P.M. 20 Draw down 0 feet 2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours