WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 18772
Permit No.
Basin 084

1. OWNER Milt Champion ADDRESS 4300 Pasture View Dr.
Parcel 23217 Palomino Valley Unit 1
Res. add. 4681 Aster Dr. Reno 89502
2. LOCATION NW ¼ SW ¼ Sec. 23 T. 22 N/S R. 21 E. Washoe County
PERMIT NO. 077-154-15

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay		0	4	4
gravel & rocks		4	7	3
clay & sand		7	60	53
gravel & clay		60	81	21
gravel		81	84	4
clay & gravel		84	87	3
clay		87	90	3
sand & gravel		90	93	3
clay		93	106	13
sand		106	112	6
sand & gravel		112	133	21
gravel		133	140	7
sand & gravel		140	144	4
clay & gravel		144	147	3
gravel	148	147	149	2
sand		149	153	4
sand & gravel		153	164	11
gravel		164	170	3
clay		170	192	22
clay & gravel		192	194	2
gravel	195	194	208	14
clay	208	208	239	31
gravel	240	239	242	3

this is a very accurate log

Date started 8/17, 1978
Date completed 8/19, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 242 feet
Casing record
Weight per foot approx. 17 Thickness .188

Diameter	From	To
8 5/8 O.d. inches	0 feet	242 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 85 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 85 feet to 242 feet

Perforations:
Type perforation factory sawed
Size perforation 3/32 x 3"
From 122 feet to 202 feet
From 222 feet to 242 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 40 ft. Feet below land surface 40
Flow ..... G.P.M. approx. 100
Water temperature Cold °F. Quality Clear

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul Williams
Address 275 Courtney Lane, Reno
Nevada contractor's license number 14483
Nevada driller's license number 957
Signed Paul Williams
Date 8/20/78

USE ADDITIONAL SHEETS IF NECESSARY

5471