CLIENT'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 18776
Permit No. 26910
Basin 35561

1. OWNER M. S. PEAK (BURT MEYER) ADDRESS 6 MILE CANYON Rd LYON COUNTY NEV

2. LOCATION SE ¼ NE ¼ Sec. 32 T. 17 N/S R. 22 E. LYON Co
PERMIT NO. 26910

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotar
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY DIRT		0	2	2'
CAVY SAND		2	10	8'
hard br. CLAY		10	34	24'
SAND + broken gray		34	45	11'
SAND		45	49	4'
Loose gray	✓	49	53	4'
Br CLAY		53	78	25'
gray + SAND		78	91	13'
Same with CLAY		91	95	4'
gray + SAND	✓	95	117	22'
Cemented gray		117	135	18'
Same CLAY STREAK		135	152	17'
COARSE SAND + GRAY CLIPS	✓	152	165	13'
SAND + CLAY STREAK		165	185	20'
COARSE SAND + GRAY	✓	185	196	11'
SAND, GRAY CLAY STREAK		196	211	15'
SANDY CLAY		211	223	12'
Same with GRAY		223	249	26'
LAYERED, SAND GRAY CLAY		249	279	30'
ROUND GRAY, CLAY TRACES	✓	279	290	11'
Same more CLAY		290	296	6
GRAY, + COARSE SAND	✓	296	300	4'
CLAY, brown		300		

Date started ..... 19.....
Date completed ..... 19.....

7. WELL TEST DATA

depth

Pump RPM	G.P.M.	Draw Down	After Hour Pump
101	423	48	4
102	418	42	44
100	423	47	5

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8" inches Total depth 300'
Casing record .....
Weight per foot ..... Thickness 188

Diameter	From	To
..... inches	..... feet	..... f
..... inches	..... feet	..... f
..... inches	..... feet	..... f
..... inches	..... feet	..... f
..... inches	..... feet	..... f
..... inches	..... feet	..... f

Surface seal: Yes ☒ No ☐ Type READY MIX
Depth of seal 55' f
Gravel packed: Yes ☒ No ☐
Gravel packed from 55' feet to 300' f

Perforations:
Type perforation .....
Size perforation .....
From 70' feet to 300' fe
From ..... feet to ..... fe
From ..... feet to ..... fe
From ..... feet to ..... fe
From ..... feet to ..... fe

9. WATER LEVEL
Static water level 53' Feet below land surface .....
Flow ..... G.P.M. .....
Water temperature COOL °F. Quality CLEAR

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true t the best of my knowledge.

Name Jim U. ENLOE
Address P.O. Box 548
Nevada contractor's license number 4739A
Nevada driller's license number 794
Signed Jim U. Enloe
Date May 1, 1976

USE ADDITIONAL SHEETS IF NECESSARY