WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 18785
Permit No.
Basin 88

1. OWNER Christensen ADDRESS 15779 Fountain Off
Mt Rose Hi APN: 150-241-03

2. LOCATION SW ¼ SW ¼ Sec 36 T. 18 N/S R. 19 E. Washoe Count
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Gravel		0	40	
Blue Clay		40	85	
Sandy Clay		85	103	
Sandy Gravel	X	103	143	
Replaced by Well log 126842				

Date started 8-28, 1978
Date completed 8-29, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 10 Draw down 8 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 143 feet
Casing record 6" OD 10 gage
Weight per foot 10 gage Thickness

Diameter	From	To
6" OD Blank inches	0 feet	83 feet
6" Perf inches	83 feet	103 feet
6" Blank inches	103 feet	123 feet
6" Perf inches	123 feet	143 feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Grout
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Vert Sawed
Size perforation 3/32 x 2" (1/8" Cont.
From 83 feet to 103 feet
From 123 feet to 143 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 110 Feet below land surface 110
Flow G.P.M.
Water temperature 55 °F. Quality G

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Robertson
Address 1718 Verbena Way Sparks
Nevada contractor's license number
Nevada driller's license number 1042
Signed Charles Robertson
Date 9-2-78

USE ADDITIONAL SHEETS IF NECESSARY

5471