

OFFICE USE ONLY
 Log No. 18786
 Permit No.
 Basin.

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Bill Tremian ADDRESS At Hand Right Hand Canyon Road
 2. LOCATION SE 1/4 NW 1/4 Sec. 19 T. 22 N/S R. 22 E. Waspc County
 PERMIT NO.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DF</u>		<u>0</u>	<u>30</u>	
<u>Sandy Clay</u>		<u>30</u>	<u>95</u>	
<u>Sand & Gravel</u>		<u>95</u>	<u>107</u>	
<u>Sand Clay</u>		<u>107</u>	<u>147</u>	
<u>Hard Sand</u>	<u>x</u>	<u>147</u>	<u>178</u>	

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 178 feet
 Casing record
 Weight per foot 10 gage Thickness
 Diameter From To
6" OD Block inches 0 feet 138 feet
6" Perf inches 138 feet 178 feet
 Surface seal: Yes No Type Grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Sawed 6" center 6 Row
 Size perforation
 From 138 feet to 178 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 95 Feet below land surface 95
 Flow _____ G.P.M. 5
 Water temperature 50 ° F. Quality G

Date started 7-25, 1978
 Date completed 8-29, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Robertson
 Address 1718 Verkey Way Sparks, Nev
 Nevada contractor's license number _____
 Nevada driller's license number 1042
 Signed Charles Robertson
 Date 9-2-78

BAILER TEST
 G.P.M. 5 Draw down 45 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours