WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 18803
Permit No.
Basin

1. OWNER George Butorac ADDRESS 573 Smithridge Reno, NV.

2. LOCATION NE ¼ 04 ¼ Sec. 8 T. 20 N/S R. 19 E. Washoe County
PERMIT NO. 125

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface Silts & Gravel		0'	25'	25'
Sandy Clay		25'	50'	25'
Sand		50'	54'	4'
Clay		54'	70'	16'
Sand		70'	83'	13'
Clay		83'	112'	29'
Sand		112	116	4'
Sandy clay		116'	136'	20'
Sand & Gravel		136'	145'	9'
Clayey-Sand & Gravel		145'	186'	41'
Sand		186'	190'	4'
Gravel		190'	196'	6'
Sandy Clay		196'	204'	8'
Sand & Gravel		204'	206'	2'
Large Gravel		206'	211'	4'
Sandy clay		210'	236'	26'
Sand & Gravel		236'	249'	13'
Sandy clay		249'	257'	8'
Sand & Gravel		257'	266'	9'
Sandy-Clay		266'	306'	14'
Gravels		300'	306'	6'
Sand & Gravels		306'	310'	4'
Sandy-clay		310'	315'	5'
Sand stone		315'	355'	40'
Sand & Clay		355'	372'	17'
Gravel		372'	390	18'
Sand & Gravel		390	400	10'

Date started 3 7-28 1978
Date completed 8-6 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 400 feet
Casing record 400' 8"
Weight per foot 17 ft Thickness 188

Diameter	From	To
8 inches	0 feet	400 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 400 feet

Perforations:
Type perforation Factory
Size perforation 3/32
From 320 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Floyd Suchta
Address 2463 Rose Mary Dr.
Nevada contractor's license number 14508
Nevada driller's license number 1028
Signed H D Anderson
Date 8-6-78

USE ADDITIONAL SHEETS IF NECESSARY

5471

OFFICE
STATE ENGINEER

1978 SEP 12 AM 9 58