

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER Larry Strickland ADDRESS Box 1538  
Yandowville, Mo

2. LOCATION 1/4 34 T 14 N/S 20 E Douglas County  
 PERMIT NO. Off Johnson Lane

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Clay</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>SAND</u>		<u>20</u>	<u>25</u>	<u>5</u>
<u>CLAY</u>		<u>25</u>	<u>35</u>	<u>10</u>
<u>Sandy Clay</u>	<u>X</u>	<u>35</u>	<u>55</u>	<u>20</u>
<u>SAND</u>		<u>55</u>	<u>86</u>	<u>31</u>

8. WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 86 feet  
 Casing record 8 3/8  
 Weight per foot 16.9 Thickness 188  
 Diameter From To  
8 inches 0 feet 86 feet  
 Surface seal: Yes  No  Type CONCRETE  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation Factory  
 Size perforation 3 x 3/32  
 From 0 feet to 84 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 7-10-78, 19\_\_\_\_  
 Date completed 7-13-78, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 20 Draw down 15 feet 1 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 170 Feet below land surface  
 Flow NO G.P.M.  
 Water temperature 60/65 Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name W.D. Blain  
 Address Box 353 Dayton, Mo  
 Nevada contractor's license number 10950  
 Nevada driller's license number 929  
 Signed Clayton Fort  
 Date 9/9/78