



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER HUMPHREYS CLARK ADDRESS 11525 JNIPER, LEMMON VALLEY, NEVADA

2. LOCATION 1/4 Sec. 15 T. 21 N/S R. 19 E. WASHOE County
 PERMIT NO. _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input checked="" type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden-clay		0'	10'	10'
Decomposed-granite		10'	50'	40'
Decomposed granite-clay		50'	104'	54'
" "		104'	124'	20'
Dry Gravel		124'	129'	5'
Dry gravel, d.g.		129'	154'	25'
Dry gravel, d.g.		154'	205'	51'
Granite, sand & water		205'	247'	42'
Set pump at 168'				
Bottom of well soft 7' of rock installed				

8. WELL CONSTRUCTION

Diameter hole 6" inches Total depth 240' feet
 Casing record 240'
 Weight per foot _____ Thickness _____

Diameter	From	To
<u>6-5/8"</u> inches	<u>0</u> feet	<u>240'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 240' feet

Perforations:
 Type perforation factory sawed slots
 Size perforation 3/32X 2 1/8"
 From 192' feet to 240' feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 55' Feet below land surface
 Flow 20 G.P.M.
 Water temperature _____ ° F. Quality _____

Date started 9-4-78, 19_____
 Date completed 9-6-78, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
			<u>101873 50'</u>

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VALLEY PUMP COMPANY
 Address 7310 ESTATES RD. RENO, NEVADA
 Nevada contractor's license number 6045
 Nevada driller's license number 1044
 Signed Matthew J. Kearney
 Date 9-18-78

BAILER TEST

G.P.M.	Draw down	feet	hours