

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Frank Pelacia ADDRESS Lemille, Nevada

2. LOCATION $\frac{1}{4}$ E $\frac{1}{4}$ Sec. 26 T. 32 N/E R. 57 E Elko County
 PERMIT NO. Lot 8 Block 1 Pleasant Valley

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Gray Sandy Clay</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>Cemented Gravel</u>		<u>8</u>	<u>30</u>	<u>22</u>
<u>Brown Clay</u>		<u>30</u>	<u>55</u>	<u>25</u>
<u>Loose Gravel with clay streaks</u>		<u>55</u>	<u>70</u>	<u>15</u>
<u>Brown Clay</u>		<u>70</u>	<u>95</u>	<u>25</u>
<u>Sand & Gravel</u>	*	<u>95</u>	<u>190</u>	<u>85</u>
<u>Brown light clay</u>		<u>190</u>	<u>200</u>	<u>10</u>

(Drill & Drive from 55' to 200' dia in soft sand & gravel)

8. 0-55'-12" WELL CONSTRUCTION
 Diameter hole 5.25-8 inches Total depth 200 feet
 Casing record _____
 Weight per foot _____ Thickness 205 wall

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>201</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement Grout
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory Cut
 Size perforation 1/2 x 3/8
 From 140 feet to 190 feet
 From _____ feet to _____ feet

Date started 8-28 19 78
 Date completed 9-18 19 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 80 Feet below land surface
 Flow _____ G.P.M.
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name O.M. Gullett Drilling Co
 Address P.O. Box 41, Elko, Nev 89801
 Nevada contractor's license number 4796
 Nevada driller's license number 115
 Signed O.M. Gullett
 Date 9-19-78

BAILER TEST 45 MIN.
 G.P.M. 20 Draw down 10 feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours