WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 18962
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Chester Hillyard ADDRESS 650 Lyons, Sparks Nev. 89431

2. LOCATION ¼ W ½ ¼ Sec. 9 T. 17 N. N/S R. 25 E. Lyon County
PERMIT NO. Lot #119 Lakeside Sub Unit #2 on 2nd St.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0-	40	40
Coarse Gray "		40	80	40
Clay		80	90	10
Gray Sand		90	150	60
Gravel + Blk. "		150	170	20
Clay		170	173	3
First Water 50 ft.				

Date started 9-7, 1978
Date completed 9-13, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 & 8½ inches Total depth 173 feet
Casing record Steel
Weight per foot 12# Thickness .156

Diameter	From	To
6 5/8 inches	+1 feet	173 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 173 feet

Perforations:
Type perforation Saw Slot
Size perforation 1/8 x 3"
From 153 feet to 173 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 38 Feet below land surface
Flow 50 G.P.M.
Water temperature C ° F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Richard Fritz
Address P.O. Box 610 Verdi, Nev
Nevada contractor's license number 14251
Nevada driller's license number 943
Signed Richard Fritz
Date 9-13-78

USE ADDITIONAL SHEETS IF NECESSARY

5471