WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 18966
Permit No.
Basin 84

1. OWNER Ralph Coogan ADDRESS Army Road (5255)

2. LOCATION SE ¼ NW ¼ Sec. 10 T. 22N N/S R. 21 E. Washoe County
PERMIT NO. APN 077-100-22 Palomino V. Unit 1 10.2.1.7

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	46	
Clay W/ Sand & Gravel		46	155	
Clay W/ gravel Stks	x	155	185	
Gravel & Rock	x	185	221	

Date started 10 - 3, 1978
Date completed 10 - 6, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 10 Draw down 6 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 221 feet
Casing record 6"
Weight per foot 10 gage Thickness 10 gage

Diameter	From	To
6" Blank inches	+1 feet	161 feet
6" Perf inches	161 feet	181 feet
6" Blank inches	181 feet	201 feet
6" Perf inches	201 feet	221 feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Grout
Depth of seal 55 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Vert Sawed
Size perforation 3/32 x 2"
From 161 feet to 181 feet
From 201 feet to 221 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 154 Feet below land surface 154
Flow G.P.M. 10
Water temperature 55 ° F. Quality G

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Karl E Roberts
Address 1718 Verbena Way Sparks Nev
Nevada contractor's license number
Nevada driller's license number 1042
Signed Karl E Roberts
Date 10-10-78

USE ADDITIONAL SHEETS IF NECESSARY

5471