WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 1967
Permit No.
Basin 84

22BDA

1. OWNER Pat Inman ADDRESS 4455 Amy Rd. Palomino V. Unit 1 22-T-1-6 Pine Valley Washoe
2. LOCATION NW ¼ SW ¼ Sec. 22 T. 22 N N/S R. 21 E. Washoe County
PERMIT NO. SENW APN 077-140-06

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	4	
Sand Clay		4	89	
Rock & Clay		89	115	
Sand & Gravel		115	210	
		210	236	
Layers Rock & Gravel	x	236	288	

Date started 9-11, 1978
Date completed 9-18, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 15 Draw down 6 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 288 feet
Casing record 8" 188 Wall
Weight per foot 188 Thickness

Diameter	From	To
8" Blank inches	0 feet	208 feet
8" Perf inches	208 feet	228 feet
8" Blank inches	228 feet	248 feet
8" Perf inches	feet	feet
inches	248 feet	288 feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Grout
Depth of seal 52 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 52 feet to 288 feet

Perforations:
Type perforation Vert Saw
Size perforation 3/32 x 2"
From 208 feet to 228 feet
From 248 feet to 288 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 169 Feet below land surface 169
Flow G.P.M.
Water temperature 50 ° F. Quality G

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles E Robertson
Address 1718 Verdi Way Sparks
Nevada contractor's license number
Nevada driller's license number 1042
Signed Charles E Robertson
Date 9-30-78

USE ADDITIONAL SHEETS IF NECESSARY

5471