WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 18979
Permit No.
Basin 8-103 DAYTON V.

1. OWNER Dale Peak ADDRESS 1409 Siskiou Carson City, Nev.

2. LOCATION se ¼ se ¼ Sec. 29 T. 16 N/S R. 21 E Lyon County
PERMIT NO.

3. TYPE OF WORK
New Well ## Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic # Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable # Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand & Clay | | 0 | 55 | 55 |
| Sand & gravel | | 55 | 95 | 40 |
| Well is rocked from 87 to 95 | | | | |

Date started 10-5-78, 19
Date completed 10-10-78, 19

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 20 Draw down 10 feet 4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 5/8 inches Total depth 95 feet
Casing record
Weight per foot Thickness 188

| Diameter | From | To |
|---|---|---|
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ## No ☐ Type Ready Mix
Depth of seal 50 feet
Gravel packed: Yes ☐ No ##
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3/16
From 55 feet to 95 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 45 Feet below land surface
Flow G.P.M. 20
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jim House & Sons Drilling
Address P.O. Box 2192 Carson City, Nev.
Nevada contractor's license number 12554
Nevada driller's license number 651
Signed Steve House
Date 10-15-78

USE ADDITIONAL SHEETS IF NECESSARY

5471