

Ph. 577-2529

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Merle Ezra ADDRESS Sub. #6 Parcel 22, Silver Springs,
 2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec. 2 T. 17 N/S R. 24 E. Lyon County
 PERMIT NO.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
gravel & clay		0	6	
brown shale		6	191	
gray shale	380	191	238	
black shale	439	238	450	

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 450 feet
 Casing record
 Weight per foot 16 Thickness 219
 Diameter 6 7/8 inches From 0 feet To 450 feet
 Surface seal: Yes No Type Cement
 Depth of seal 150 feet
 Gravel packed: Yes No
 Gravel packed from 150 feet to 450 feet
 Perforations:
 Type perforation factory sawed
 Size perforation 3/32 x 3
 From 410 feet to 450 feet

Date started 10/7 1978
 Date completed 10/9 1978

9. WATER LEVEL
 Static water level 300 Feet below land surface
 Flow 38 G.P.M.
 Water temperature cold F. Quality clear

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Paul Williams
 Address 275 Courtney Lane Reno, NV
 Nevada contractor's license number 19483
 Nevada driller's license number 9577
 Signed Paul Williams
 Date 10/9/78

BAILER TEST
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours