WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 19026
Permit No.
Basin

1. OWNER Tom Ratliff ADDRESS 94 Rainbow Dr Dayton, Nev 89403

2. LOCATION NW 1/4 of SW 1/4 Sec. 27 T. 17 N/S R. 22 E. Lyon Co County
PERMIT NO. Lot #94 Pinewood View

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Rock | X | 80 | 95 | 15 |
| Sand & gravel | | 95 | 128 | 33 |

Well already drilled by Labrum to 80'

Date started 9/25/78, 19
Date completed 9/26/78, 19

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 10 Draw down 10 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8" 80-128' inches Total depth 128 feet
Casing record 8 5/8
Weight per foot 16.9 Thickness 188

| Diameter | From | To |
|---|---|---|
| 8 inches | 0 feet | 128 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Bentonite
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 100 feet

Perforations:
Type perforation Factory
Size perforation 3 x 3/32
From 106 feet to 126 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 83 Feet below land surface
Flow G.P.M.
Water temperature Cold F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wm. Blair
Address Box 353 Dayton, Nev
Nevada contractor's license number 10950
Nevada driller's license number 963
Signed R. O'Farrell
Date 10/23/78

USE ADDITIONAL SHEETS IF NECESSARY

S471