

Log No. 19034  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER John F. Abbri ADDRESS 1769 Camille Dr  
CC, NV

2. LOCATION S 1/2 1/4 Sec. 29 T. 16 N/S R. 21 E. Lyon County  
 PERMIT NO. 21-0001 View Estates Sub 179 February 50 South

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	25	25
Gravel & Clay		25	60	
Clay		60	80	20
Sub & Boulder	X	80	95	15

8. WELL CONSTRUCTION  
 Diameter 4 1/2 inches Total depth 95 feet  
 Casing record 8 5/8  
 Weight per foot 16.9 Thickness 18.8

Diameter	From	To
8 inches	0	95

Surface seal: Yes  No  Type no water  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation Factory  
 Size perforation 2 1/2 3/4  
 From 72 feet to 92 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 2-15-78, 19\_\_\_\_  
 Date completed 2-13-78, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 20 Draw down 10 feet 1 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 55 Feet below land surface  
 Flow N/S G.P.M.  
 Water temperature 60.1 Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W. M. Blain  
 Address Box 353 Dayton, NV  
 Nevada contractor's license number 10950  
 Nevada driller's license number 929  
 Signed Clay Post  
 Date 10/3/78