

WELL DRILLERS REPORT

Please complete this form in its entirety

Log No. 19248  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

1. OWNER LES ENSMINGER ADDRESS 1158 HOPKINS  
Napa, Ca 94558  
 Site: 11205 Wagon Ho  
 2. LOCATION NE 1/4 SE 1/4 Sec. 32 T. 24 N/S R. 18 E. WASHOE County  
 PERMIT NO. 384

3. TYPE OF WORK	New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	4. PROPOSED USE	Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Test <input type="checkbox"/>	5. TYPE WELL	Cable <input type="checkbox"/>	Rotary <input checked="" type="checkbox"/>
	Deepen <input type="checkbox"/>	Other <input type="checkbox"/>		Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>		Other <input type="checkbox"/>	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown clay		0	5	5
decomposed granite w/clay stringers		5	55	50
decomposed granite		55	95	40
blue clay		95	125	30
decomposed granite		125	140	15
coarse water sand	XX	140	165	15
decomposed granite		165	200	35
brown clay		200	230	30
coarse water sand, good	XX	230	252	22
brown clay		252	256	4

8. WELL CONSTRUCTION

Diameter hole 12 1/4 inches Total depth 256 feet  
 Casing record 8 5/8" od x 188 wall  
 Weight per foot 16.94 Thickness \_\_\_\_\_

Diameter	From	To
<u>12 1/4</u> inches	<u>0</u> feet	<u>256</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type cement grout  
 Depth of seal 52 feet  
 Gravel packed: Yes  No   
 Gravel packed from 52 feet to 256 feet

Perforations:  
 Type perforation Milled  
 Size perforation 3" x 1/8"  
 From 136 feet to 256 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started November 17, 19 78  
 Date completed November 20, 19 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1800	25	100	10

9. WATER LEVEL

Static water level 5 Feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature 60 ° F. Quality GOOD

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SAGE BROS DRILLING CO., INC.  
 Address 1500 EAST RANGER RD RENO, NV 89506  
 Nevada contractor's license number 7462A  
 Nevada driller's license number 935  
 Signed Larry Martin  
 Date December 22, 1978

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours