WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 11302
Permit No.
Basin

1. OWNER RICHARD & MARILYN WALLER ADDRESS 1245 W CIENIGA SP #84 SAN DIMAS CALIF

2. LOCATION NW ¼ SE ¼ Sec. 5 T. 12 N/S R. 21 E. DOUGLAS County
PERMIT NO. LOT 40 FISH SPRINGS ESTATES

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	3	3
BROWN CLAY		3	15	12
BOULDERS & SAND	✓	15	18	3
GRAVEL & CLAY		18	40	22
BROWN CLAY		40	55	15
GRAVEL & CLAY		55	80	25
SAND & GRAVEL	✓	80	100	20

Date started 12-8, 19~~79~~ 78
Date completed 12-27, 19~~79~~ 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 15 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8" inches Total depth 100 feet
Casing record 8 5/8" x 100'
Weight per foot Thickness .188

Diameter	From	To
8 5/8 inches	0 feet	100 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CEMENT GROUT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation MILL
Size perforation 1/8" x 2
From 60 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 15 Feet below land surface
Flow 30 G.P.M. FROM 40'
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ACE PUMP SALES & SERVICE
Address 5551 Highway 50 E, #5 Carson City, Nev. 89701
Nevada contractor's license number 015489
Nevada driller's license number 203
Signed James W Thompson
Date 1-17-79

USE ADDITIONAL SHEETS IF NECESSARY

5471