

OFFICE USE ONLY  
 Log No. 19393  
 Permit No. 2224 9255  
 Basin. 179 DE 116

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER GEORGE PANAGOPOULOS ADDRESS 931 Ave K. ELY, NEV.

2. LOCATION S/W 1/4 S/E 1/4 Sec 23 T. 16 N S R. 63 E WHITE PINE County  
 PERMIT NO. 23124 30235

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	
clay		2	10	
Sandy clay		10	50	
Clay		50	88	
sand	*	88	92	4
Clay		92	130	
Sand & Gravel	*	130	138	8
Clay		138	147	

8. WELL CONSTRUCTION  
 Diameter hole 14 inches Total depth 147 feet  
 Casing record.  
 Weight per foot \_\_\_\_\_ Thickness 1/4  
 Diameter From To  
103/4 inches 1 feet 147 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet

Surface seal: Yes  No  Type Ready-Mix  
 Depth of seal 0 To 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 147 feet

Perforations:  
 Type perforation Machined  
 Size perforation 1/8  
 From 85 feet to 145 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 57 Feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature cool ° F. Quality Good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Name JIM SCHOOLER  
 Address BOX 833  
Ely, Nev.  
 Nevada contractor's license number 9557  
 Nevada driller's license number 515  
 Signed Jim Schooler  
 Date 1/10/79

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours