

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER William Atwell ADDRESS Box 422
GARDENVILLE NV 89400

2. LOCATION SE 1/4 SW 1/4 Sec. 33 T. 15 N R. 20 E. CC County
 PERMIT NO. EDMUND DR

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Clay</u>		<u>0</u>	<u>43</u>	<u>43</u>
<u>Coarse Dgt</u>	<u>X</u>	<u>43</u>	<u>54</u>	<u>11</u>
<u>Dgt Clay</u>		<u>54</u>	<u>80</u>	<u>26</u>
<u>Clay</u>		<u>80</u>	<u>82</u>	<u>2</u>
<u>Coarse Sand</u>		<u>82</u>	<u>104</u>	<u>22</u>
<u>Clay</u>		<u>104</u>	<u>105</u>	<u>1</u>

8. WELL CONSTRUCTION
 Diameter hole 8" 8 1/2 inches Total depth 105 feet
 Casing record 8 1/2
 Weight per foot 16.9 Thickness 1.88

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>105</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Concrete 50' feet
 Depth of seal Concrete 50' feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Factory
 Size perforation 3 x 3/32
 From 82 feet to 102 feet
 From _____ feet to _____ feet

Date started 2/12/79, 19_____
 Date completed 2/12/79, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 20 Draw down 15 feet 2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level _____ Feet below land surface 45
 Flow _____ G.P.M.
 Water temperature Cold ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name W.M. Blain
 Address Box 353 Dayton, NV
 Nevada contractor's license number 10950
 Nevada driller's license number _____
 Signed Charles Rabe
 Date 3/10/79