WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 19412
Permit No.
Basin

1. OWNER Ed Katzoki ADDRESS Virginia Highlands LOT 262 BLOCK 77

2. LOCATION NE ¼ NE ¼ SE¼ Sec. 32 T. 17N N/S R. 21 E. STOREY County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN CLAY		0	4	4
CLAY & BOULDERS		4	25	21
SMALL GRAVEL		25	30	5
FRACTURED GRAYSHALE		30	60	30
GRAY HEAVY CLAY-SHALE		60	175	115
GRAY WATER BEARING SHALE	195	175	200	25
T.D.=200				

Date started 3-7- 1979
Date completed 3-8- 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
BLEW WELL FOR 1 HR TO DEVELOP			
650 C.F.M	-250 P.S.I.		

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. 10 5/8 TO 50' WELL CONSTRUCTION
Diameter hole 8 3/4 inches Total depth 200 feet
Casing record 6 5/8
Weight per foot 12.9 Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CONCRETE
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation FACTORY
Size perforation 1/16-3
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 50' Feet below land surface
Flow 15 G.P.M.
Water temperature COLD ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AQUA DRILLING & WELL SERVICE INC
Address P.O. BOX 2143
Nevada contractor's license number 15291
Nevada driller's license number 1062
Signed Edward A. Harrison
Date 3-8-79

USE ADDITIONAL SHEETS IF NECESSARY