WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 19538
Permit No.
Basin

1. OWNER ERNIE ZEBAL ADDRESS MARGARET, GOLDEN VALLEY, NEVADA

2. LOCATION ¼ ¼ Sec. 20 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. 18900 Mesquite, Cold Springs, Nevada, Washoe County

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden, sand, clay		0'	10'	10'
gravel, clay, sand		10'	54'	44'
gravel, sand some water		54'	79'	25'
gravel, sand		79'	104'	25'
gravel, sand and water		104'	130'	26'
Set pump at 100'				

Date started 9-27-78, 19
Date completed 9-28-78, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6" inches Total depth 130 feet
Casing record 130'
Weight per foot Thickness

Diameter	From	To
6-5/8 inches	0 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 130 feet

Perforations:
Type perforation factory sawed slots
Size perforation 3/32 X 2½"
From 70' feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 29' Feet below land surface
Flow 30 G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VALLEY PUMP COMPANY
Address 7310 Estates Rd. Reno, Nevada
Nevada contractor's license number 6045
Nevada driller's license number 1044
Signed 9-30-79
Date Matthew J. Kearney

USE ADDITIONAL SHEETS IF NECESSARY

5471