WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 19669
Permit No.
Basin

PAGE 1 of 2

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER STANLEY BARNES ADDRESS Box 138 Kings River Star Rte, Orovada Nevada

2. LOCATION SW ¼ NW ¼ Sec. 36 T. 46 N R. 33 E. Humboldt County
PERMIT NO. 17039

3. TYPE OF WORK
Replacement
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Reverse

6. LITHOLOGIC LOG
S+G = Sand + Gravel

Material	Water Strata	From	To	Thickness
Top Soil		0	7	
S+G		7	199	
Clay		199	203	
S+G		203	222	
Clay		222	223	
S+G		223	226	
Clay		226	228	
S+G		228	233	
Clay		233	236	
Clay + gravel		236	240	
S+G		240	255	
Clay		255	259	
S+G		259	267	
Clay		267	269	
S+G		269	280	
Clay		280	282	
S+G		282	291	
Clay		291	299	
S+G		299	308	
Clay		308	309	
S+G		309	313	
Clay		313	318	
S+G		318	324	
Clay		324	328	
S+G		328	345	
Rocks S+G		345	357	
Clay + Sand		357	363	

cont. on pg 2

Date started 4-13, 1979
Date completed 4-14, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 28 inches Total depth 403 feet
Casing record
Weight per foot Thickness

Diameter	From	To
16 inches	0 feet	259 feet
12 inches	259 feet	403 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 403 feet

Perforations:
Type perforation Roscoe Moss Full +
Size perforation Standard Flow Louvered
From Std Flow 184 feet to 208 feet
From Full Flow 208 feet to 256 feet
From " " 257 feet to 281 feet
From Std " 281 feet to 305 feet
From Full " 305 feet to 353 feet

continued on pg 2

9. WATER LEVEL
Static water level Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Plaskett Irrigation Co.
Address PO Box 8 Eureka Nv
Nevada contractor's license number 11882
Nevada driller's license number 706
Signed Walter Plaskett
Date 4-19-79

USE ADDITIONAL SHEETS IF NECESSARY

5471

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 19666
Permit No.
Basin

Page 2 of 2

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Stanley Barnes ADDRESS

2. LOCATION SW ¼ NW ¼ Sec. 36 T. 46 N/S R. 33 E. Humboldt County
PERMIT NO. 17039

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐

6. LITHOLOGIC LOG cont From pg 1

S+G = Sand + Gravel

Material	Water Strata	From	To	Thickness
Clay		363	364	
Clay + Sand		364	369	
S+G		369	377	
Clay		377	381	
S+G		381	383	
Clay		383	385	
S+G		385	390	
Clay		390	395	
S+G		395	400	
Clay		400	403	

Date started ....., 19.....
Date completed ....., 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole ..... inches Total depth ..... feet
Casing record .....
Weight per foot ..... Thickness .....

Diameter	From	To
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes ☐ No ☐ Type .....
Depth of seal ..... feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation .....
Size perforation ..... continued from page 1
From Stl Flow 353 feet to 377 feet
From Full " 377 feet to 401 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level ..... Feet below land surface .....
Flow ..... G.P.M. .....
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Plaskett Drr. Co.

Address .....

Nevada contractor's license number .....

Nevada driller's license number .....

Signed .....

Date .....

USE ADDITIONAL SHEETS IF NECESSARY

5471