WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 19721
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER [illegible] ADDRESS 10655 WELLS FARGO SILVER KNOLLS 89506

2. LOCATION SE ¼ NE ¼ Sec. 26 T. 21 N/S R. 18 E. MDB&M County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
[illegible]				
[illegible]				
[illegible]			2	1
COARSE SAND & some TRAY CLAY	X	227	243	16
gray CLAY		243	245	2+

Date started 4-17-, 19 79
Date completed 4-20-, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 25 Draw down 70 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 9 7/8 inches Total depth 245 feet
Casing record 6 5/8 OD
Weight per foot Thickness .156

Diameter	From	To
6 5/8 OD inches	+1 feet	245 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CEMENT
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 245 feet

Perforations:
Type perforation 1/8" X 3" FACTORY
Size perforation
From 205 feet to 245 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 90' Feet below land surface
Flow G.P.M.
Water temperature COLD ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ACE DRILLING & DEVELOPMENT
Address 10655 Silver Knolls BLVD
Nevada contractor's license number 14[illegible]
Nevada driller's license number 1037
Signed [illegible]
Date 4-20-79

USE ADDITIONAL SHEETS IF NECESSARY

5471