WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 19272
Permit No. 35499
Basin

1. OWNER Rilite Aggregate Co. ADDRESS P.O. Box 5665 Reno, Nevada 89510

2. LOCATION SW ¼ NW ¼ Sec. 23 T. 18 (N) S R. 20 E. Washoe County
PERMIT NO. ~~36392~~ 35499

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [ ] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [X] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill material		0	20	20
White to grey material		20		
loose -large chips		20	35	15
As above - also red chips				
still loose		35	65	30
White to grey to tan in				
color - slower drlg.		65	80	15
As above but more loose				
probably water bearing		80	100	20
White to grey w/smaller				
chips - more granular-				
slower drlg w/ some frac-				
tured areas		100	115	15
TEST HOLE:				
As above but much				
harder		115	147	32

Date started 11-11, 19 78
Date completed 1-03, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
421 GPM @ 80' depth after 8 hours			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 20 inches Total depth 115 feet
Casing record 0-115 x 12 3/4 OD
Weight per foot 33.38 Thickness .250

Diameter	From	To
20 inches	0 feet	115 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type Cement Slurry
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 115 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/16 x 3"
From 60 feet to 102 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 65 Feet below land surface
Flow ..... G.P.M.
Water temperature 113 °F. Quality Test in progress

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
Address P.O. Box 404 Sparks, Nevada 89431
Nevada contractor's license number 9767
Nevada driller's license number 493
Signed W.L. McDonald
W.L. McDonald
Date 1-4-79

USE ADDITIONAL SHEETS IF NECESSARY

5471