WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 19784
Permit No.
Basin 102

APN 17-451-08

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Ed Griffith ADDRESS 240 Penelope Dr Sparks NV 89431

2. LOCATION ~~SE~~ NE ¼ ~~SW~~ NW ¼ Sec. ~~20~~ 29 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. Silver Springs = Catfish & Cougar

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	28	28
Clay		28	40	12
Fine Sand	X	40	55	15
Coarse Sand		55	93	38
Gray Clay		93	95	2

Date started 4-9-79, 19
Date completed 4-13-79, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 10 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12" 50' 45' 8" inches Total depth 95 feet
Casing record 8 5/8
Weight per foot 16 9 Thickness 188

Diameter	From	To
8 inches	0 feet	95 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3 x 3/32
From 73 feet to 93 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 35 Feet below land surface
Flow No G.P.M.
Water temperature Cold Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W. M. Blair
Address Box 353 Dayton NV
Nevada contractor's license number 10950
Nevada driller's license number 1027
Signed William Rinehart
Date 5/10/79

USE ADDITIONAL SHEETS IF NECESSARY

5471