WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 17157
Permit No.
Basin

1. OWNER MIKE PITTS ADDRESS 8805 Military Rd. Reno, Nevada

well location 8670 Jerome Lemon Valley Parcel # 86-411-17

2. LOCATION ¼ ¼ Sec. 4 T. 20 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	4	4
light brn granite med hard		4	54	50
light green granite med "		54	81	27
blue granite hard		81	101	20
white granite med hard.		101	153	52
blue green granite hard w/fract.	x	153	175	22

Date started 5/30/79, 19
Date completed 5/2/79, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 175 feet
Casing record 175 ft.
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	175 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 ft. feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 175 feet

Perforations:
Type perforation factory sawed slot.
Size perforation 3/32 x 2½ x 6 around
From 135 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 35 Feet below land surface
Flow 15 G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING INC.
Address P. O. Box 12370 Reno, Nevada 89510
Nevada contractor's license number 14043
Nevada driller's license number #817
Signed Frank Rodella
Date 6-4-79

USE ADDITIONAL SHEETS IF NECESSARY

5471