WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 19959
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER MESQUITE CORPORATION ADDRESS 360 Gault Sparls, Nevada 89431

Lot 21 Block C on Cartwright Virginia City Highlands, Nev. ~~Sub~~ Cartwright

2. LOCATION NE ¼ NW ¼ Sec. 32 T. ~~12~~ 18 N/S R. ~~18~~ 21 E. Story County

PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	2	2
yellow clay		2	35	33
green hard rock		35	110	75
gray rock		110	120	10
green hard rock	xx	120	175	55

Date started 5/23/79, 19
Date completed 5/24/79, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 175 feet
Casing record 175 ft.
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	175 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 ft. feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 175 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2½ x 6 around
From 155 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 45 Feet below land surface
Flow 10 G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING INC.
Address P. O. Box 12370 Reno, Nevada 89510
Nevada contractor's license number 14043
Nevada driller's license number #923
Signed El Mendenger
Date 5-25-79

USE ADDITIONAL SHEETS IF NECESSARY

5471