

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Harold A. Lipska ADDRESS 1345 Callahan Rd

2. LOCATION Unit 1 - Lot 59 Subdivision
1/4 NE 1/4 Sec. 2 T. 17 N/S R. 19 E Washoe County
 PERMIT NO.

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	2	2
Boulders w/ Clay & Sand		2	85	83
D.G with Clay		85	130	45
D.G + Gravel 2-GPM	137	130	160	30
Fractured D.G.	160	160	180	20
T.D.			180	

8. 10 5/8 - 50' WELL CONSTRUCTION

Diameter hole 8 3/4 inches Total depth 180 feet
 Casing record 658
 Weight per foot 10.9 Thickness 10 ga

Diameter	From	To
<u>6 7/8</u> inches	<u>0</u> feet	<u>180</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type Concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 180 feet

Perforations:
 Type perforation factory
 Size perforation 1/2 x 3/8
 From 1.44 feet to 180 feet
 From feet to feet

Date started 5-18, 19 79
 Date completed 5, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with 250 PSI air Pon 40 min to develop			

BAILER TEST

G.P.M.	Draw down.....feethours
G.P.M.	Draw down.....feethours
G.P.M.	Draw down.....feethours

9. WATER LEVEL

Static water level 120 Feet below land surface
 Flow 12 G.P.M.
 Water temperature 60.0 °F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aque Drilling & Well Service
 Address 2255 Glendale Spark NV
 Nevada contractor's license number 15271
 Nevada driller's license number 932
 Signed Albert Cady
 Date 5-21-79