WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 20844
Permit No.
Basin

1. OWNER Steve Erisman ADDRESS Gardnerville

2. LOCATION SE ¼ NE ¼ Sec. 6 T. 12 N/S R. 21 E. Douglas County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay + Rock | | 0 | 60 | 60 |
| Gravel | W/B | 60 | 90 | 30 |
| Clay + Gravel | | 90 | 95 | 5 |

Date started 6-4, 19 79
Date completed 6-12, 19 79

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 15 Draw down 0 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 5/8 inches Total depth 95 feet
Casing record
Weight per foot Thickness 188

| Diameter | From | To |
|---|---|---|
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3/32
From 54 feet to 95 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 50 Feet below land surface
Flow G.P.M. 15
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name JIM HOUSE & SONS DRILLING
Address P.O. Box 2192 Carson City, NV 89701 882-0338
Nevada contractor's license number 12554
Nevada driller's license number 651
Signed Steve House
Date 3-29-80

USE ADDITIONAL SHEETS IF NECESSARY

5471