WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 21585
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Chris Christeffersen ADDRESS 4401 W Ames st. Silver Springs
Lot 53

2. LOCATION ¼ ¼ Sec. 28 T. 18 N/S R. 24 E. Lyon County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Rock		0	20	20
Soft rock +		20	280	260
Brown Clay		280	300	20
Rock		300	329	29

This well was Cased to 300 ft + drilled out to 329 + Back filled with 3/8 - gravel to 300 ft. this was done to increase flow rate.
CRS

Date started June 28, 19 80
Date completed June 30, 19 80

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blown	15	0	2 HC

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10" inches Total depth 329 feet
Casing record 6 5/8
Weight per foot 9.28 Thickness .130

Diameter	From	To
6 5/8 inches	0 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 200 feet to 329 feet

Perforations:
Type perforation Factory
Size perforation 3/32 x 3
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 80 Feet below land surface 220
Flow 0 G.P.M. 15
Water temperature Cold ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul Williams
Address 22 South Patterson
Nevada contractor's license number 14483
Nevada driller's license number 1001
Signed Jim R. Stream
Date 6/30/80

USE ADDITIONAL SHEETS IF NECESSARY

5471