WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 22042
Permit No.
Basin

HOME BUILDERS ASSOC. of NV.

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER HIGH SIERRA CONST. ADDRESS 480 IDAHO
RENO NV. 89506

2. LOCATION NW ¼ NE ¼ Sec. 15 T. 21 N/S R. 19E E. WASHOE County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE SOIL		0'	2'	2'
COARSE SAND		2'	90'	88'
D.G. + GRAY CLAY		90'	100'	10'
HARD FRACTURE D G	—	100'	140	40'

Date started SEPT. 20, 1980
Date completed SEPT. 27, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 22 Draw down 8 feet 8 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 5/8 inches Total depth 140' feet
Casing record 6 5/8 x 188 WALL
Weight per foot Thickness 188

Diameter	From	To
18" inches	0 feet	30 feet
10 5/8 inches	30 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type NEAT CEMENT
Depth of seal 55 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 55 feet to 140 feet

Perforations:
Type perforation MILL CUT
Size perforation 3/8
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 103 Feet below land surface 103
Flow G.P.M.
Water temperature COLD ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ACE DRILLING + DEVELOPMENT
Address 10655 SILVERKNOLLS BLVD RENO NV
Nevada contractor's license number 14299
Nevada driller's license number 1203
Signed ~~Welon~~ Welon T Sage
Date OCT 13, 1980

USE ADDITIONAL SHEETS IF NECESSARY

5471