WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

no card

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 22113
Permit No.
Basin

1. OWNER Ben McCully Const. ADDRESS Carson City, Nev.

2. LOCATION se ¼ sw ¼ Sec. 18 T. 20 N/S R. 20 E. Douglas County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand & Clay | | 0 | 50 | 50 |
| Sand | w/b | 50 | 97 | 47 |

Date started Oct 17.1980, 19
Date completed Oct 22,1980, 19

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 12 Draw down 70 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 5/8 inches Total depth 97 feet
Casing record
Weight per foot Thickness 188

| Diameter | From | To |
|---|---|---|
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 1/16
From 77 feet to 97 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 8 Feet below land surface
Flow G.P.M. 12
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jim House & Son's Drilling
Address P.O. Box 2192 Carson City, Nev
Nevada contractor's license number 12554
Nevada driller's license number 651
Signed Steve House
Date Nov.5,1980

USE ADDITIONAL SHEETS IF NECESSARY

O-627