WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 22161
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER WILLIAM HARRIS ADDRESS 25900 FETLOCK DR.

2. LOCATION SW ¼ SW ¼ Sec. 33 T. 24 N/S R. 18 E. WASHOE County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE SOIL		0	1	1
HARD PAN		1	8	7
D.G.	—	8	40	32
BROWN CLAY & D.G.		40	45	5
D.G & BROWN CLAY		45	100	55
D.G & VOLCANIC GRAVEL + GRAY CLAY	—	100	140	40
D.G. & FINE SAND	—	140	200	60

Date started SEPT 12, 1980
Date completed SEPT 17, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 15 Draw down 60 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 200 feet
Casing record 8⅝
Weight per foot Thickness .188

Diameter	From	To
18 inches	0 feet	60 feet
12¼ inches	60 feet	20 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 52 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 52 feet to 200 feet

Perforations:
Type perforation MILL CUT
Size perforation 3/16 X 3
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 11 Feet below land surface 11'
Flow G.P.M.
Water temperature COLD ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ACE DRILLING
Address 10655 SILVER KNOLLS BLVD RENO
Nevada contractor's license number 14299
Nevada driller's license number 1203
Signed [signature]
Date SEPT 22, 1980

USE ADDITIONAL SHEETS IF NECESSARY

5471