WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 22171
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER A. Rand ADDRESS 560 Gardenway Carson City

2. LOCATION ¼ ¼ Sec. T. N/S R. E. Washoe County
PERMIT NO.

3. TYPE OF WORK: New Well ☐ Recondition ☐ Deepen ☑ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gray clay & shale		310	585	
Tuffaceous red shale		585	615	
Tuffaceous sandstone		615	630	
Red tuffaceous sandstone		630	680	
Hard tuffaceous sandstone with fractures		680	750	
Fractured shale		750	775	

Date started 11/26/80, 19
Date completed 11/29/80, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 5 7/8 O.D. inches Total depth 775 feet
Casing record
Weight per foot 1.5 Thickness .250

Diameter	From	To
5 7/8 O.D. inches	275 feet	775 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation factory screen
Size perforation
From 715 feet to 775 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 180 ft Feet below land surface
Flow G.P.M. approx. 6
Water temperature 60 ° F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul Williams
Address 22 S. Pollard, Sparks
Nevada contractor's license number 14482
Nevada driller's license number 257
Signed Paul E. Williams
Date 11/22/80

USE ADDITIONAL SHEETS IF NECESSARY

O-627