WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 22247
Permit No.
Basin

1. OWNER John Tomasevic ADDRESS 1345 Dennis St Minden, Nev.

2. LOCATION SW ¼ SE ¼ Sec. 33 T. 14 N/S R. 20 E. Douglas County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand & Clay | | 0 | 55 | 55 |
| Sand | W/S | 55 | 98 | 43 |

Date started 12-9-80, 19
Date completed 12-15-80, 19

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 16 Draw down 45 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 5/8 inches Total depth 98 feet
Casing record
Weight per foot Thickness 188

| Diameter | From | To |
|---|---|---|
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3/32
From 78 feet to 98 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 20 Feet below land surface
Flow G.P.M. 16
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jim House & Sonos Drilling
Address P.O. Box 2192 Carson City, Nev.
Nevada contractor's license number 12554
Nevada driller's license number 651
Signed Steve House
Date 12-15-80

USE ADDITIONAL SHEETS IF NECESSARY

O-627