WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

CDCC

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 22250
Permit No.
Basin 88

1. OWNER Mr. Winburn ADDRESS Mt. Rose Highway

2. LOCATION SE ¼ SW ¼ Sec. 34 T. 18N N/S R. 19 E. Washoe County
PERMIT NO. W05442760

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☒

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Yellow clay		0	30'	30'
fractured basalt rock		30	55	25'
" " "		55	70	15'
fractured granite		70	82'	12'
fractured sedimentary rock		82'	92'	10'
sand, gravel, water		92'	105'	13'
~~X~~ sand, gravel, water		105'	120'	15'

Date started 11-17-80, 19
Date completed 11-19-80, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1½ H.P.	25	90'	24 hrs.

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8-5/8 inches Total depth 120 feet
Casing record
Weight per foot Thickness

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 1 Feet below land surface
Flow 25 GPM G.P.M.
Water temperature cold ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VALLEY PUMP COMPANY
Address P.O. BOX 624, SPARKS, NEV. 89431
Nevada contractor's license number 6045
Nevada driller's license number 1123
Signed [signature]
Date 11-28-80

USE ADDITIONAL SHEETS IF NECESSARY

5471