

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER W.K. Tower Inc. S.E.A. Engineers & Planners ADDRESS 20559 Treasure Hwy Suite 201 Langley B C Canada
950 Industrial Way Sparks, Nev.

2. LOCATION Belli Ranch Reno, Nevada
 1/4 Sec. 22 T. 19 N/S R. 18 E. Washoe County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brn clay w/granite boulders		0	45	45
brn clay		45	65	20
gray volcanic rock	xx	65	215	150
dark gray volcanic rock	xx	215	300	85
215 water B.				
290 "				
295 "				

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 300 feet
 Casing record 300 ft.
 Weight per foot _____ Thickness 1.56

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>300</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 300 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 2 1/2 x 6 around
 From 210 feet to 300 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 130 Feet below land surface
 Flow 33 G.P.M.
 Water temperature _____ ° F. Quality _____

Date started Dec 14, 1980
 Date completed Dec. 27, 1980

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Name WAYNE DRILLING, INC.
 Address P. O. Box 12370 Reno, Nevada 8910
 Nevada contractor's license number 14043
 Nevada driller's license number 923
 Signed Ed Mondragon
 Date 12-27-80

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours