WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 22327
Permit No. 39992
Basin

1. OWNER Swift Builder — ADDRESS
7-11- Store - Rancho Estates -
2. LOCATION ¼ ¼ Sec. 10 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. 39992

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well ☒ Recondition ☐	Domestic ☒ Irrigation ☐ Test ☐	Cable ☒ Rotary ☐
Deepen ☐ Other ☐	Municipal ☐ Industrial ☐ Stock ☐	Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt + Boulders		0	15	15
Cobble stones and Clay		15	30	15
Boulders and Heavy gravel some clay		30	70	40
Course gravel and Cobble stones - Clay		70	82	12
Heavy Gravel		82	100	18
Mostly water at 70 to 100 ft.				
				100

Date started 1-9, 1981
Date completed 1-15, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 15 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 8 5/8 inches Total depth 100 feet
Casing record
Weight per foot 19 Thickness 188

Diameter	From	To
8 5/8 inches	0 feet	100 feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from 0 feet to 50 + feet

Perforations:
Type perforation Factory
Size perforation 1/8 x 3
From feet to feet
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 17 Feet below land surface
Flow G.P.M.
Water temperature 56 ° F. Quality EX

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Austin W. Graham
Address P.O. Box 1976 - Gardnerville
Nevada contractor's license number 12953
Nevada driller's license number 751
Signed A.W. Graham
Date 1-15-81

USE ADDITIONAL SHEETS IF NECESSARY

O-627