

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Dr. Allen ADDRESS 2190 Dart Reno
 2. LOCATION 1/4 Sec. 27 T. 19 N/S R. 19 E. Washoe County
 PERMIT NO.....

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. Heat PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
gravel + pebbles		0	50	50
Brown clay		50	130	80
Blw clay w/s sand		130	450	320
Blw clay		450	512	62
Brown clay slab w/s sand		512	575	63
gravel packed 350 to 575				
cement + clay pack to 250 ft				
gravel packed from 250 to 50 ft				
0 to 50 cement				
well mud temp	50	65°		
	255	76°		
	500	94°		
	510	102°		
	575	104°		

8. WELL CONSTRUCTION
 Diameter hole 13 in inches Total depth 575 feet
 Casing record.....
 Weight per foot..... Thickness 1.88
 Diameter From To
8 inches 0 feet 575 feet
 inches feet feet
 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 350 feet to 575 feet
50 250
 Perforations:
 Type perforation slot
 Size perforation 1/8
 From 4.50 feet to 575 feet
 From feet to feet
 From feet to feet
 From feet to feet

Date started 12-20, 1980
 Date completed 1-11, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level..... Feet below land surface 80
 Flow..... G.P.M.....
 Water temperature 170 ° F. Quality.....

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Brinkhoff Pump & Drill Co Inc
 Address 1026 Winnemucca Ave
 Nevada contractor's license number 12265B
 Nevada driller's license number 1161
 Signed [Signature]
 Date 1-11-81

BAILER TEST
 G.P.M. 20 Draw down 25 feet 2 hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours