WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 22470
Permit No. 52566
Basin 4-71

1. OWNER A.L. Boyd ADDRESS 12000 S. Grass Valley Rd. Winn. Nev.

2. LOCATION NE ¼ NW ¼ Sec. 13 T. 34 N/S R. 37 E. Pershing County
PERMIT NO. APN 009-120-35
JSC 2/27/2012

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil Brn.		0	2	
Clay Brn.		2	7	
Gravel Lg. Brn.		7	22	
Clay Sandy Brn.		22	30	
Gravel Small Brn.		30	34	
Clay Sandy Brn.		34	54	
Sand & Gravel Brn.		54	89	
Gravel w/Sand Brn.	yes	89	103	14
Clay Brn.		103	105	

Date started 2-4, 1981
Date completed 2-10, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 40 Draw down 60 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 105 feet
Casing record
Weight per foot 10 lbs. Thickness 106A.

Diameter	From	To
6 inches	0 feet	105 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation torch
Size perforation 1/8 x 6
From 85 feet to 103 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 25 Feet below land surface
Flow G.P.M.
Water temperature 54 °F. Quality Average

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.C. Stites
Address 7495 Cloud Burst Winn. Nev.
Nevada contractor's license number 016578
Nevada driller's license number 1145
Signed A.C. Stites
Date 2-10-81

USE ADDITIONAL SHEETS IF NECESSARY

5471