WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 22496
Permit No. 30940
Basin

1. OWNER ZIMMERMAN RANCHING CORP. ADDRESS ROUND MOUNTAIN, NEV 89045

2. LOCATION ~~SE~~ SW ¼ SE ¼ Sec. ~~11~~ 4 T. 12 N N/S R. 43 E NYE County
PERMIT NO. ~~30941~~ 30940

3. TYPE OF WORK
New Well XX Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation XX Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary X
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	12	12
SAND & GRAVEL W/S BR. CLAY		12	40	28
SAND & GRAVEL W/CLAY STRINGERS		40	75	35
BR. CLAY		75	85	10
SAND & GRAVEL		85	90	5
BR. CLAY		90	100	10
SAND & GRAVEL		100	110	10
BR. CLAY		110	115	5
SAND & GRAVEL W/S CLAY		115	160	45
LARGE GRAVEL & SAND		160	170	10
SAND & SM. GRAVEL W/LG. ROCKS		170	205	35
SAND & GRAVEL & LITTLE BR. CLAY		205	246	41
SAND & GRAVEL		246	253	7
SOFT BR. CLAY W/LITTLE BR. CLAY		253	256	3
SAND & GRAVEL W/LITTLE BR. CLAY		256	265	9
SAND & GRAVEL		265	270	5
SOFT BR. CLAY		270	278	8
SOFT BR. CLAY W/SAND & GRAVEL		278	282	5
SAND & GRAVEL		282	286	4
SAND & GRAVEL W/SOFT GREY CLAY		286	293	7
SAND & GRAVEL		293	298	5
GREY CLAY W/LITTLE SAND & GRAVEL		298	312	14
SAND & GRAVEL		312	380	68
GREY CLAY W/SAND & GRAVEL		380	408	28

Date started January 12, 1981, 19
Date completed January 20, 1981, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	1100	250'	10 hrs.

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 24 inches Total depth 408 feet
Casing record 16"
Weight per foot Thickness ¼

Diameter		From		To	
16" Blank	inches	0	feet	120	feet
16" Perf	inches	120	feet	408	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☐ No XX Type
Depth of seal feet
Gravel packed: Yes XX No ☐
Gravel packed from 0 feet to 408 feet

Perforations:
Type perforation ROSCOE MOSS SCHUTTER SCREEN
Size perforation 1/8"
From feet to feet
From SEE ABOVE feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BRAD SANTUCCI #1153
Address 6860 W. Rosecreek Road Winnemucca, Nev 89445
Nevada contractor's license number 015234
Nevada driller's license number 1153
Signed Brad Santucci
Date Feb 24 1981

USE ADDITIONAL SHEETS IF NECESSARY

O-627