WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 22568
Permit No. 36207
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER F.E.G. & Cox ADDRESS 2655 Hyland Dr.
Well Site # 1

2. LOCATION ¼ ¼ Sec. T. N/S R. E. Churchill County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil Sand		0	28	28
Sand (Fine)	✓	28	42	14
Black Clay		42	52	10
Black Sand	✓	52	78	26
Blk. Sand & Clay Strips	✓	78	82	04
* Rough Sand	✓	82	93	11
Brown Clay		93	99	06
Quick Sand	✓	99	106	07
Brown Clay		106	112	06
Fine Sand	✓	112	120	08
Green Clay		120	125	05
Sand	✓	125	128	03
Black Clay		128	145	17
Quick Sand	✓	145	153	08
Blue Clay		153	159	06
Blk. Sand & Clay Strips		159	180	21
Green Clay		180	182	02
Blue Sand	✓	182	186	04
Grey Clay		186	194	08
Blue Sand	✓	194	196	02
Green Clay		196	199	03
Sand	✓	199	203	04
Quick Sand	✓	203	209	06
Brown Clay		209	210	01
Blue Clay & Sand		210	219	09
Quick Sand	✓	219	234	15
Grey Clay		234	249	15

Date started November, 19 78
Date completed December, 19 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	25	40	400

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 5 inches Total depth 321 feet
Casing record
Weight per foot Thickness .188

Diameter	From	To
8 inches	01 feet	321 feet
12 inches	0 feet	50 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Grout
Depth of seal Surface to 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from — feet to — feet

Perforations:
Type perforation Torch Cut
Size perforation 3/16
From 312 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 273 Feet below land surface 48
Flow 1 ¼ G.P.M. Un Tested
Water temperature Cold °F. Quality Excellent

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Paul N. Pflimlin
Address 7007 Curry Rd.
Nevada contractor's license number 10655
Nevada driller's license number 928
Signed Paul N. Pflimlin
Date Feb. 1, 1979

USE ADDITIONAL SHEETS IF NECESSARY

5471